

METOS Hardware options and configuration

Teraterm Application for configuring METOS hardware

Agri-tech Client Dashboard & Charting tools for Substrate & Soil Production



Contents

| | |
|---|---------|
| Product Identification | 3 |
| Hardware Version details and sensor options | 4 - 5 |
| Agri-tech Auto-drain station | 6 |
| 0390 / 0310 Data Transfer Units wiring and specs | 7 - 10 |
| ATS22 Data Transfer Units - October 22 onwards | 11 - 13 |
| Wiring and calibration of the pH / EC interface (auto-drain) | 14 |
| Wiring the two pH / EC interface units into the ATS22 DTU | 15 |
| LoRain configuring / battery replacement | 16 - 17 |
| LoRath configuring / battery replacement pre April 2022 | 18 |
| LoRath configuring / battery replacement post April 2022 | 19 |
| Teraterm for configuring METOS Loggers | 20 - 22 |
| APN Settings for various networks | 23 |
| Teraterm for configuring the ATS 22 DTU (data transfer unit) | 24 - 27 |
| Agri-tech Client Login / Dashboard / Charting tools (substrate) | 28- 30 |
| Entering crop observations & fungicides for the Mildew model | 31 |
| Agri-tech Dashboard / Charting tools (soil) | 32 - 33 |


What product have you got?



1. M-Metos Soil Base - DTU with rain gauge



2. METOS ATS22 - DTU



3. pH/Ec Interface




4. LoRain—Collector



5. Lorath - Temp/RH sensor



6. Cabled Temp/RH Sensor



METOS Hardware



METOS DTU (Data Transfer Unit) pre October 2022

1 = solar panel

2 = DTU chassis

ID numbers would start 0390 pre Jan 22

ID numbers would start 0310 Jan 22 -
October 2022 - Field Scale Basic
October 22 onwards



METOS DTU (Data Transfer Unit) post
October 2022 (Fruit Advanced System)

ID numbers would start 0021 October 22
onwards



METOS LoRath (temperature / humidity)
pre March 2022

ID numbers would start 03B0



METOS LoRath (temperature / humidity)
post March 2022

ID numbers would start 03B0 or 04C1

METOS Hardware - contd



METOS LoRain pictured with solar panel.
NB Units pre October 2022 did not have solar panels fitted

ID numbers would start 03A0 (no solar)
04D0 with solar

METOS DTU Sensors



Sentek SDI 12 moisture probes (60cm, 30cm)



Cabled Temp/RH Sensor



pH / EC interface unit with sensors



Rain Gauge




Rain Gauge with added EC / pH sensor well

Agri-tech Auto-drain Station




Hardware consists of 1 DTU, 2 rain gauges with sensor well fitted, 2 pH / EC interfaces and 2 each of pH & EC sensors

Fully automated measurement 24/7 of your drip and drain pH / EC and run-off



Micro METOS NBIoT DTU (data transfer unit) - 0390 / 0310 units




Re-set button

Micro USB for Comms cable


SIM holder

IM523 Rain Gauge plug

IM 526 Temperature / humidity Sensor wiring or
With plug on to I2C EXT



pH / EC interface wiring on to 0390 / 0310 board




Micro METOS NBloT DTU (data transfer unit) - 0390 / 0310 units



6.1 Inputs and connectors

Front side:



Picture 4 - Front side of the μMETOS NBloT motherboard (29-0409) with labeled elements

| Number | Label | Description |
|--------|-----------------|---|
| 1 | | internal connectivity test button |
| 2 | PRESS SW | Pressure switch input |
| 3 | USB | Micro-B USB port |
| 4 | SIM | Micro SIM card slot |
| 5 | I2C Ext | I2C Extension port input |
| 6 | SW LED | External button with LED status connector |
| 7 | RAIN | Rain gauge or Water meter sensor input |
| 8 | WIND | Anemometer or Counter sensor input |
| 9 | DC/PIB-1 | DC (duty cycle) for Pyranometer sensor input or PI-Bus sensor input |
| 10 | HC2 | Hygroclip sensor input |
| 11 | LEAFW | Leaf wetness sensor input |
| 12 | TEMP-1 | (DS18B20) - dedicated soil temperature sensor input |
| 13 | TEMP-2 | (DS18B20) - dedicated air temperature sensor input |
| 14 | BAT | 6V battery connector |
| 15 | SOL | Solar panel connector |
| 16 | WATERMARK 1A 1B | 1 st watermark sensor input |
| 17 | WATERMARK 2A 2B | 2 nd watermark sensor input |
| 18 | SENS-1 | Decagon/METER Group sensor / PI-Bus sensor input |
| 19 | SENS-2 | Decagon/METER Group sensor / PI-Bus sensor input |
| 20 | SDI-12 | SDI12 sensor input |
| 21 | PIB-2 (RS485) | General PI sensor bus input |

Lights on the board are as follows:

Orange LED - powering up

Red LED - Obtaining GPS position and sensor testing (takes 3-5 minutes)

Blue LED - Modem powering up


Green LED - TX (transmission)

Micro METOS NBloT DTU (data transfer unit) - 0390 / 0310 units



Power up sequence:

1. connect the battery to the BAT connector, make sure the polarity is correct, negative (-) is on the left side and positive (+) terminal is on the right side for the battery connector
2. connect the solar panel to the SOL connector, make sure the polarity is correct, negative (-) is on the right side and positive (+) terminal is on the left side for the solar connector



Picture 12 – Power inputs labeled polarity on the board



Picture 13 – Left: Battery cable, right: solar panel cable

Common color scheme:

Battery cable:


- WHITE cable is negative (-), connected to the – battery terminal
- BROWN cable is positive (+), connected to the + battery terminal

Solar panel cable:




- RED cable is positive (+)
- BLACK cable is negative (-)

Be very careful: if you connect the wrong power source to a wrong power input or if you reverse the polarity on any power input the motherboard can have issues and possible burnout. In such case, the motherboard will have to be replaced.

Micro METOS NBIoT DTU (data transfer unit) - 0390 / 0310 units



- 1) Hex securing screws (2.5mm)
- 2) 2.5mm Hex driver
- 3) Upper casing
- 4) Lower casing
- 5) Battery
- 6) Comm port
- 7) SIM holder




To access the battery, SIM card holder & Comm port

Remove the six hex screws using the 2.5mm hex driver and split the upper case from the lower case. On the 0390 units the six hex screws are on the lower casing of the unit, on the 0310 (pictured) they are located on the upper casing

METOS ATS22 - DTU Base PCB

DTU wiring diagram including pH/EC Interface & SDI 12 port for Moisture Probe



Interface:


- A) SDI-12 board (Sentek moisture probe)
- B) LED indicators
- C) Connect button
- D) Battery connector
- E) Solar panel connector
- F) Jumper 2
- G) Jumper 1
- H) USB connector - Teraterm
- I) Boot jumper
- J) Reset button
- K) Antenna connections
- L) SIM Holder

Sensor inputs:

- 1) WIND iMETOS® 3 2ozn
- 2) INPUT
- 3) LEAF
- 4) INPUT 2 (temp / rh)
- 5) INPUT 3
- 6) INPUT 4
- 7) Rain Gauge (Drip in)
- 8) INPUT 1
- 9) Rain Gauge (Run-off)
- 10) HC2 B
- 11) HC2 A
- 12) Direct Pibus (chain) input (pH / EC Interface)

(On Field Climate 7 = channel 9, 9 = channel 5)

METOS ATS22 - DTU Base PCB—Jumpers



BOARD JUMPER

The ATS22 board is equipped with 3 board jumpers;

BOOT Jumper— As pictured above (I) This jumper is only required when updating or replacing a firmware—**PLEASE NOTE—THE BOARD WILL CEASE TO COMMUNICATE WITH BOOT JUMPER IN PLACE—THIS MUST BE REMOVED AFTER USE**

Jumper 1— (G) Terminal Mode—For use when connected to the board via TeraTerm (Normal use)


Jumper 2— (F) Modem Mode— For use when testing via external modem (Rare use)

NOTE:

It is possible to 'VIEW' the ATS22 board without any Jumpers in order to view live activities—


It is **NOT** possible to make any changes or run any commands without the correct Jumper in place

METOS ATS22 - DTU - October 22 onwards




Component layout:

- 1) System Enclosure
- 2) Battery housing
- 3) Solar Panel mount
- 4) System mounting plate



pH/EC Interface Unit



Wiring inputs:

- A) Wiring to Extension board
- B) Wiring to DTU Base
- C) pH Sensor
- D) EC Sensor
- E) LCD Display
- F) Configuration control buttons
- G) Display mode button
- H) Battery



Calibration controls:

1. ON/ENTER to wake device
2. UP to select pH or EC sensor to calibrate
3. ON to start calibration process insuring sensor is submerged within the buffer liquid
4. LCD display will confirm to 'WAIT' during the calibration process
5. 'DONE' will be displayed to confirm successful inc calibrated value in either EC or pH value




Agri-tech Auto-drain Station

Wiring diagram of the two pH / EC interface units into the DTU for drip and drain pH / EC. For wiring the two rain gauges for run-off into the ATS22 DTU please refer to page 11




Wiring inputs:

- A) pH / EC interface unit 1
- B) pH / EC 1 wired into pH / EC 2
- C) pH / EC unit 2 wiring
- D) pH / EC unit 2 into DTU
- E) pH Sensor input
- F) EC sensor input



Configuring the LoRain sensor



Carefully press the outer edge of the rain collector body to release the locating peg on the rain tipper body

Locating peg




Once the first peg is released remove tipper unit from the rain gauge body



Use the 2.5mm Hex driver (supplied) to remove the 6 hex securing screws



Carefully open up the battery cover



Insert the micro SIM into the SIM holder as pictured far left and slide the SIM securing holder closed

Carefully connect the battery (left) to the SCAP terminal

Configuring the LoRain sensor—contd



Remove the rubber band to free the tipper

Replace the six hex screws but DO NOT overtighten these



Carefully replace the tipper into the Rain Gauge body by carefully pushing out against the body to secure

Measure the distance between the two bolts (supplied) and drill a hole in a suitable steel / stainless pole



Secure the sensor to the pole and attach the pole using strong cable ties or jubilee clips

If installing into the soil, install the mount pole before securing to the sensor to avoid damage



Please email info@agri-tech.co.uk the serial number and key 1 number found on device

The Comms cable may be required to check settings on the device - accessed by the port pictured left.

When emailing Agri-tech please state serial number, key 1 number, field name and specify run-off / or drip in. In addition please state number of drippers in the bags / pots, and number of bags / pots you are collecting run-off from.

Configuring the LoRath sensor - pre April 2022



1



2

1 LoRath Sensor measuring temperature & humidity

2 Dedicated serial number When emailing Agri-tech please state serial number, key 1 number, & field name



3




4

3 Use the 2.5mm Hex driver (supplied) to remove the 6 hex securing screws

4 Carefully open up the battery cover



5




6

5 PCB

Temperature / humidity sensor - take care not to touch / damage this when replacing the unit cover - avoid over tightening hex screws

6 PCB - showing SIM housing



7



8

7 Carefully connect the battery to the SCAP terminal

Please email info@agri-tech.co.uk the serial number and key 1 number found on device


8 The Comms cable may be required to check settings on the device - accessed by the port pictured left.

Configuring the LoRath sensor - post April 2022




To configure the device and change / connect the battery, remove the four Phillips screws pictured on the front of the enclosure

Please email info@agri-tech.co.uk the serial number and key 1 number found on device



Component layout:

- 1) Modem
- 2) SIM card holder
- 3) Temperature / humidity sensor
- 4) Battery connector
- 5) Solar Panel connector
- 6) Comms port (underside of board)




Using Tera Term to check sensor readings, signal strength & comms etc - all METOS hardware **except AT22 DTU**

C

Click on to the Tera Term icon pictured to open up the programme. Ensure that the METOS device you are Connecting to is powered up and that you have the cable securely inserted into the unit




Remove the Comms cover and connect the comms cable as shown above. Not all METOS units will have port access such as is pictured above, LoRATH and LoRain units do. The probe DTU units do not but may have a flying lead as an access point.



NB See note below ref com port allocation

When Tera Term opens up - select the Serial option. If this is not being displayed you will need to go into Device Manager, go down to ports and check that the port is being allocated. To do this insert the comms cable and you should see a comm port being allocated under Device Manager if the device is recognised. For information on Device

Manager see next page



Device Manager Tips

In Device Manager click on the > by Ports and expand this.

In the expanded section you should see a com port being allocated as you plug the cable in and out of your USB port on your PC / Tablet. This will give you the port number you should see available to you when you open up Tera Term (pictured on previous page)

Using Tera Term to check sensor readings, signal strength & comms

MAIN MENU:

```
1 - Print system info
2 - Print last raw data of data memory
3 - Print all raw data of data memory
4 - Print sensors configuration set
5 - Sensor testing
6 - Print all control registers of data memory
7 - Print DataFlash memory organization
8 - Make a new sensors configuration set
A - System setup
F - Enter switch-off mode

L - Print NB IoT info
P - Setup NB IoT module parameters
M - NB IoT modem bridge mode
T - Test (force) data transmission
Z - FH Upgrade
```

Main Menu

Once you have connected to the device press Escape and H to display the main menu

iMetos NB IoT - System info:

```
Hardware version:    v1.10
Hardware ID:        29-0404
Device ID:          76
Device type:        nMETOS80
Firmware version:   v1.33
Firmware revision date: 2022-06-15 10:55:00
Device description: LoRAIN NB IoT / nMETOS Station
Serial Number:      03B0ED2A
Current date and time: 2000-01-01 00:04:44
```

```
Status of measurement: running
Next alarm time:      00:15:00
Measure interval [sec.]: 900
Logging interval [sec.]: 900
Transmission int. [sec.]: 3600
Max. number of data pkts: All
```

```
NB IoT stack version: v1.14
NB IoT stack revision date: 2022-06-14 15:58:00
```

```
USB stack version:   v1.04
USB stack revision date: 2020-10-13 11:52:00
```

```
Bootloader version: v1.05
Bootloader revision date: 2020-11-22 15:07:00
Bootloader description: BOOT24_1024GB606
```

Press H for help.

System info

Pressing menu option 1 will display the system info.

This will highlight the device description (this example a Lorain device) and the serial number.

The serial number together with the Key 1 found on the device label is what needs to be sent to Agri-tech to set the device up in the correct monitoring block

Serial number in this example is 03B0ED2A

Sensor testing:

| Input | Full Name Of Sensor | Short | Value | Unit | Notes |
|-------|-------------------------|-------|-------|------|-------|
| | Battery voltage | BATTR | 3339 | mV | |
| | Solar Panel | SOLPN | 1182 | mV | |
| | I2C Air temperature | AIRTH | 22.59 | C | |
| | I2C Relative humidity | RELH | 46.4 | % | |
| | DeltaT | DELT | 6.97 | C | |
| | Dew point | DEHPT | 10.54 | C | |
| | Vapour pressure deficit | VPD | 1.46 | kPa | |

Note: Press 8 to save a new sensor configuration set.

Done.

Press H for help.

Sensor Test

Pressing menu option 5 will conduct a sensor test and will give a value from each sensor connected. In this example it is a LoRath (temperature and humidity logger)

Temp is 22.59 Celsius and humidity 46.4%.

When installing a moisture probe, check the readings here to make sure you have a good install - readings with values less than 10 is usually due to air gaps from a poor install. In this instance re-install to achieve improved readings

Using Tera Term to check sensor readings, signal strength & comms

Making a new sensor configuration set

```
Do you really want to make a new sensors configuration set? [Y - Yes / N - No]
New sensors configuration set:
AMS sensor config... restored!
Done.
Press H for help.
```

If you add a new sensor, it's good practice to go to menu option 8 to make a new sensor configuration set. This should ensure the sensors appear server end under sensor configuration. If they do not appear here there will be no data coming into the server for that particular sensor. Option 4 will give you the current configuration saved to check all sensors.

```
SETUP THE NB-IOT MODULE PARAMETERS:
1 - IP ADDRESS           -> 80.122.185.10
2 - REMOTE PORT          -> 33332
3 - APN NAME             -> zest4.com
4 - LOGIN                -> zest4
5 - PASSWORD             -> zest4
6 - REGISTRATION TIMEOUT -> 240 sec.
7 - OPERATOR SELECTION  -> Automatic
8 - RADIO ACCESS TECHNOLOGY -> GSM
9 - TRANSFER PROTOCOL   -> UDP
D - Set the default parameters
F - NB-IoT FOTA
U - NB-IoT Module FW Upgrade
Press ESC to return to MAIN MENU.
Press H for help.
Press ESC to return to MAIN MENU.
```

```
Current Radio Access Technology: NB1
Select new one or escape [ESC]:
1 - NB1
2 - CAT-M1
3 - GSM
4 - AUTO RAT SELECTION
```

```
Press H for help.
NB-IoT module - System info:
Server IP Address:      80.122.185.10
Server Remote Port:    33332
APN name:               None
Login:                  None
Password:               None
Registration timeout:   240 sec.
Operator selection:     Automatic
Radio Access Technology: NB1
Modem Model:           HL7800
Modem SW Version:      HL7800.4.4.6
Modem Revision ID:     HL7800.4.4.6.0
IMEI:                  354616090495024
SIM Card ID (ICCID):   89882390000123426317
IMSI:                  901288003969090
Last connection status:
Signal Strength:        49 %
Network type:           roaming
Network name:           DATA ONLY
Registration time:      1 sec.
```

Changing from NB-IoT to CAT-M or GSM

When switching between differing networks, there will be the need to connect the METOS device to Teraterm in order to set the APN for the network and configure the device for either NB-IoT or CAT-M

To switch from NB-IoT to CAT-M

1. Press H to display the menu
2. Press P to get sub-menu
3. Press 3 to change APN name
4. Display will ask if you want to change the APN Y/N click Y
5. Press 3 again and type in the APN eg zest4.com
6. Press 4 for login and type zest4
7. Press 5 for password and type zest4
8. Press 8 for Radio Technology and choose CAT-M

You have now changed the device from NB-IoT to CAT-M. Now conduct the test by going to the main menu and choosing T for test.

NB Pre January 2022 systems will not have option 3 - GSM

Signal Strength Test

To test the signal strength press H for the menu followed by T. This will run through some diagnostics and assuming you have signal will give you an indication of the signal strength in the vicinity of the sensor.

Once this has finished press H again for the menu then press L to get the NB-IoT system report (pictured) - the signal strength result will be displayed

Ideally the signal strength will be 30%

APN Settings for various networks

Settings for direct Vodafone cards is as follows;

1. APN = `iot.comm-tech.co.uk`
2. Login = none
3. Password = none

For international roaming Vodafone

1. APN = `lpwa.comm-tech.co.uk`
2. Login = none
3. Password = none

For indirect Vodafone SIM cards

1. APN = `arkessalp.com`
2. Login = `arkessa`
3. Password = `arkessa`

For 2G GSM

1. APN = `internet`
2. Login = `web`
3. Password = `web`
- 4.

For CAT-M

1. APN = `zest4.com`
2. Login = `zest4`
3. Password = `zest 4`

Telstra settings ATS22 units

Country: Australia

User APN MCC: 505

User APN MNC: 01

User APN name: `telstra.m2m`

User name: "" (=none)

Password: "" (=none)

For Telstra (Australia)

1. APN = `telstra.wap`
2. Login = none
3. Password = none

Telstra Australia (open SIMS)

APN = `telstra.internet`



Login none (ATS22 none = "")

Password = none (ATS22 none = "")

Configuring your METOS modem for Australia / Tasmania—Telstra

1. Open Tera Term
2. Press H to bring up the main menu followed by M
3. Then enter `at+kcarriercfg=13`
4. Press H again followed by M
5. Enter `at+kbndcfg=1,8000000` then press Enter & ESC - this is now configured for the Telstra Network

Using Tera Term to check sensor readings, signal strength & comms on the ATS22 DTU



Items you will need before using Teraterm



USB Comms cable Jumper placed on port J1 of the DTU

Without the jumper you will not be able to interrogate the unit

Having installed Teraterm from the web suggest creating a short cut on the desktop (item 1) Connect the Comms cable (1)



When opening up Teraterm the screen new connection will appear (item 2). Click on the serial button and click ok. If this fails to work use Device Manager to determine the correct Comm port to use, (refer to page 20 for detail)

Having successfully connected you will get to the main menu (item 3), whereby you have the option of choosing system, sensors and modem.

For a quick view of the system click option 1 on the menu (highlighted in item 4). This will provide a quick summary of the system.

The important points here are the station number which should tally up with the sticker found inside the enclosure on the ATS22 device, (item 5)

The APN settings may also become relevant is you experience network issues as these are the settings for each network's SIM to communicate across the cloud. If different SIMS are used then the APN settings will need changing (item 6)



Changing the SIM card APN settings on the ATS22 DTU

```
=====
USER: \ MAIN MENU
=====
(1)  SYSTEM
(2)  SENSORS
(3)  MODEM
07/11/2022 15:36:16 >> Chosen function: MODEM
```

1. From the main menu choose option 3 Modem
2. From the modem menu choose option 1 modem settings
3. Let the modem go through its settings and eventually the modem settings menu will appear. Choose option 5 APN of customer
4. The current APN settings will appear.
5. To change these from the "Choose the action" menu click D to delete defined user APN.
6. Then choose I to insert new APN access.

```
=====
USER: \ MAIN MENU \ MODEM
=====
(1)  MODEM SETTINGS
(3)  SEND STATION DATA
(4)  GET GPS
(5)  GET CONF SMS
(6)  Download FH
(7)  Download APN list
(ESC) BACK
```

```
OK
AT+CNUM
OK
SIM's MCC: 204
SIM's MNC: 04
SIM's CCID: 8944538532020610949
SIM's CIMI: 204046990888099
SIM's PIN: READY
```

```
=====
USER: \ MAIN MENU \ MODEM \ MODEM SETTINGS
=====
(1)  GET MODEM INFO
(2)  SEND IDENTIFICATION SMS
(3)  UNLOCK SIM CARD (PIN CODE)
(4)  SIGNAL QUALITY GRAPH
(5)  APN OF CUSTOMER
(A)  Check available APNs
(ESC) BACK
07/11/2022 15:37:42 >> Chosen function: APN OF CUSTOMER
```

To enter a new APN access you will need the following

- a) User APN country
- b) User APN MCC
- c) User APN MNC
- d) User APN Name
- e) User APN user name
- f) User APN password

```
=====
USER: \ MAIN MENU \ MODEM \ MODEM SETTINGS \ APN OF CUSTOMER
=====
USER APN SETTINGS:
-----
User APN Country:  "uk"
User APN MCC:      "204"
User APN MNC:      "04"
User APN Name:     "mobiledata"
User APN User Name: ""
User APN Password: ""
CHOOSE THE ACTION:
-----
(I)  INSERT NEW APN ACCESS
(D)  DELETE DEFINED USER APN
(ESC) BACK
07/11/2022 15:44:23 >> Select...|
```

Once this has been entered choose ESC to go back. Pressing ESC enough times will take you back to the main menu eg System, Sensors, Modem

To determine the SIM MCC, and SIM MNC put the SIM card into the SIM holder and power up the device. The start up process will interrogate the SIM and will automatically display the SIM MCC and MNC which can then be entered into the APN settings. The APN, user name and password will also be required as supplied by the SIM provider.

- a. User APN country is free text so enter country name in here eg UK
- b. User APN MCC is the mobile country code (UK is 234) Australia MCC = 505
- c. User APN MNC is the mobile network code (Vodafone is 15) Telstra MNC = 01
- d. User APN name is the APN of the network (Vodafone is internet)
- e. User APN user name and password - some APN's have user names and passwords, if both are none then the "" represents none

Some APN settings for a number of networks can be found on page 23 login an passwords that are none = "" on the ATS22

Testing Sensors connected to the ATS22 DTU

When installing a new system, or re-installing a moisture probe for example it's important to conduct a sensor test to ensure the readings are valid

1. To conduct a sensor test from the main menu choose option 2 sensors
2. The sensor menu will now appear. From this menu choose T do sensor test
3. The Do sensor test menu will now appear.
4. For the main sensors connected to the DTU choose 0, Main+Duty+HC2 sensors. These will include the solar panel, temperature / humidity and various other sensors
5. For the SDI 12 Sentek moisture probe choose option 7 Extended Input B
6. For the pH / EC unit choose option 5 Dedicated chain
7. Press ESC to go back
8. If ESC fails press Q (quit)

```
=====
USER: \ MAIN MENU
=====
(1)  SYSTEM
(2)  SENSORS
(3)  MODEM

07/11/2022 16:00:19 >> Chosen function: SENSORS
=====
USER: \ MAIN MENU \ SENSORS
=====
(B)  BATTERY STATUS
(T)  DO SENSOR TEST
(W)  WIRELESS SYSTEM
(I)  ACCEPT CONFIGURATION + DO RECORD
(P)  PRINT LAST MEASURED DATA
(S)  PRINT LIST OF SUPPORTED SENSORS
(E)  PRINT ENCODED RECORDS
(C)  DELETE SENSOR CONFIGURATION
(R)  DELETE ALL RECORDS
(D)  DELETE CONFIGURATION + RECORDS
(Y)  SET ULTRASONIC ZERO WITH CURRENT HEIGHT
(Z)  SET ULTRASONIC ZERO WITH 2 METERS
(O)  SDI12
(1)  Assign type of temperature sensors to inputs 1 to 3
(2)  Select Leaf wetness or pressure switch for the LH input
(ESC) BACK
```

```
=====
USER: \ MAIN MENU \ SENSORS \ DO SENSOR TEST
=====
(0)  MAIN + DUTY + HC2 SENSORS
(1)  CHAIN AT INPUT 1
(2)  CHAIN AT INPUT 2
(3)  CHAIN AT INPUT 3
(4)  CHAIN AT INPUT 4
(5)  DEDICATED CHAIN
(6)  EXTENDED INPUT A
(7)  EXTENDED INPUT B
(8)  WIRELESS CHAIN
(A)  ALL SENSORS
(ESC) BACK

07/11/2022 16:02:50 >> Select...|
```

> Chosen function: EXTENDED INPUT B

```
=====
USER: \ MAIN MENU \ SENSORS \ DO SENSOR TEST \ EXTENDED INPUT B
=====

Sensors automatic test in progress
Yellow LED indicate active measurement
Press 'Q' for quit

@SSN      @SMST      @SMST      @SMST      @SSDD      @SSDD      @SSDD      @SOIT      @SOIT      @SOIT
33809     19969     19969     19969     20228     20228     20228     17153     17153     17153
CH0/7     CH1/7     CH2/7     CH3/7     CH4/7     CH5/7     CH6/7     CH7/7     CH8/7     CH9/7
4024     0.02     0.00     0.00     238.8467  237.1041  156.1103  19.9     19.9     20.1
4024     0.02     0.00     0.00     238.8467  237.3328  155.7241  20.0     19.8     20.1
4024     0.02     0.00     0.00     239.3272  237.1041  155.9172  19.9     19.9     20.1
```

1. Soil Moisture - 30cm probe
2. Conductivity
3. Soil temperature

> Chosen function: DEDICATED CHAIN

```
=====
USER: \ MAIN MENU \ SENSORS \ DO SENSOR TEST \ DEDICATED CHAIN
=====

Sensors automatic test in progress
Yellow LED indicate active measurement
Press 'Q' for quit

@PH      @SOIT      @COND      @PHBT      @PH      @SOIT      @COND      @PHBT
32769    17153      32770      32771      32769    17153      32770      32771
CH0/5    CH1/5      CH2/5      CH3/5      CH4/5    CH5/5      CH6/5      CH7/5
8.463    19.7       3.88       3680       8.497    19.8       4.01       3680
8.463    19.7       3.88       3680       8.497    19.8       4.00       3680
8.463    19.7       3.88       3680       8.497    19.8       4.00       3680
8.463    19.7       3.88       3680       8.497    19.8       4.01       3680
8.463    19.7       3.89       3680       8.497    19.8       4.00       3680
```

1. pH - Interface unit
2. Temperature
3. EC (conductivity)

Conducting a signal strength test on the ATS22 DTU

```
=====
USER: \ MAIN MENU
=====
(1)  SYSTEM
(2)  SENSORS
(3)  MODEM
07/11/2022 15:36:16 >> Chosen function: MODEM
```

1. From the main menu choose option 3 Modem
2. From the modem menu choose option 1 modem settings
3. Let the modem go through its settings and eventually the modem settings menu will appear. Choose option 4 signal quality graph
4. The signal quality graph will give a readout of signal status (see details below)

```
=====
USER: \ MAIN MENU \ MODEM
=====
(1)  MODEM SETTINGS
(3)  SEND STATION DATA
(4)  GET GPS
(5)  GET CONF SMS
(6)  Download FH
(7)  Download APN list
(ESC) BACK
```

```
OK
AT+CNUM
OK
SIM's MCC: 204
SIM's MNC: 04
SIM's CCID: 8944538532020610949
SIM's CIMI: 204046990888099
SIM's PIN: READY
=====
USER: \ MAIN MENU \ MODEM \ MODEM SETTINGS
=====
(1)  GET MODEM INFO
(2)  SEND IDENTIFICATION SMS
(3)  UNLOCK SIM CARD (PIN CODE)
(4)  SIGNAL QUALITY GRAPH
(5)  APN OF CUSTOMER
(A)  Check available APNs
(ESC) BACK
07/11/2022 15:37:42 >> Chosen function: APN OF CUSTOMER
```

```
=====
USER: \ MAIN MENU \ MODEM \ MODEM SETTINGS \ SIGNAL QUALITY GRAPH
=====
-----
(Esc) <- exit from this menu item
-----
Signal: >..... No signal detected .....< (RSSI: 0 / BER: 99)█
```

The signal quality graph is interpreted using the following principles;

1. RSSI is the measure of the signal quality ranging from 0 - 31
2. RSSI 31 = perfect signal quality
3. RSSI 30 - 7 = signal quality okay and system will operate
4. RSSI 6 and lower = poor signal (not ideal for reliable communication)
5. BER means how often data packets have to be transmitted
6. BER 99 = not known or not detectable
7. When the message "No signal detected" as in the illustration above ideally search for another location for your system

Agri-tech Client Dashboard and Charting

NB: Client Login can be accessed from the Login button on the Agri-tech home page or from <https://dashboard.agri-tech.co.uk/>



Email Address
simon.turner@agri-tech.co.uk

Password

SIGN IN

Copyright © Agri-Tech Services Ltd. 2022.

ATS Substrate Dashboard



Moisture, EC and temp from the probes



Drip and drain EC, pH and run-off via the app OR new auto drain station



Climate sensor data

Drummond Fruit substrate Fields

| Name | Moisture | Water Usage | Conductivity | Soil Temp | Run Off % | Avg 24hr Run-Off % | Run-Off 24hr | pH In | pH Out | pH Bag | Ec In | Ec Out | Ec Bag | Ec Sum | Ambient Temp | Humidity | VPD | Mildew Risk |
|--|----------|-------------|--------------|-----------|-----------|--------------------|--------------|-------|--------|--------|-------|--------|--------|--------|--------------|----------|------|-------------|
| FRONT DRIVE 22 | 29.46 | 0.01 | 1.44 | 14.83 | N/A | N/A | 25.00% | 5.60 | 6.20 | 6.60 | 1.10 | 1.30 | 1.55 | 2.40 | N/A | N/A | N/A | N/A |
| STABLE DRIVE 22 MALLING SUPREME | 16.23 | -0.01 | 1.50 | 14.50 | N/A | N/A | 50.00% | 5.70 | 7.00 | 6.50 | 1.00 | 1.20 | 1.46 | 2.20 | 14.10°C | 84% | 2.56 | N/A |
| STABLE FAR 22 ARABELLA POTS 2ND YR PPU | 21.62 | -0.04 | 1.56 | 15.08 | N/A | N/A | 45.00% | 5.70 | 7.00 | 6.50 | 1.00 | 1.20 | 1.46 | 2.20 | 14.28°C | 80% | 3.20 | 17 hours |
| FRONT ORCHARD 22 ARABELLA (BARE ROOT) | 32.01 | -0.02 | 1.61 | 14.53 | N/A | N/A | 26.00% | 5.40 | 7.10 | 6.40 | 0.90 | 1.30 | 1.42 | 2.20 | 14.23°C | 82% | 2.88 | 12 hours |
| DILO 22 FAVORI POTS 3RD YR PPU | 35.48 | -0.02 | 1.51 | 14.42 | N/A | N/A | 25.00% | 5.60 | 6.70 | 6.80 | 0.90 | 1.10 | 1.85 | 2.00 | 14.27°C | 85% | 1.92 | 15 hours |

5 rows | 1 of 6

ATS Substrate Dashboard – Phone view option on dashboard Available on both substrate and soil dashboard views



| Front Drive 22 | Stable Drive 22 Malling Supreme | Stable Far 22 Arabella Pots 2nd yr PPU | Front Orchard 22 Arabella (Bare root) | Dilo 22 Favori Pots 3rd yr PPU | Barn Field Prize 22 |
|-------------------------|---------------------------------|--|---------------------------------------|--------------------------------|----------------------------|
| Moisture: 29.41 | Moisture: 16.16 | Moisture: 27.02 | Moisture: 31.89 | Moisture: 35.37 | Moisture: 24.06 |
| Water Usage: -0.01 | Water Usage: -0.01 | Water Usage: 1.03 | Water Usage: -0.06 | Water Usage: -0.04 | Water Usage: -0.02 |
| Conductivity: 1.44 | Conductivity: 1.50 | Conductivity: 1.50 | Conductivity: 1.60 | Conductivity: 1.51 | Conductivity: 1.63 |
| Soil Temp: 14.70 | Soil Temp: 14.42 | Soil Temp: 15.00 | Soil Temp: 14.33 | Soil Temp: 14.43 | Soil Temp: 14.45 |
| Run Off %: N/A | Run Off %: N/A | Run Off %: N/A | Run Off %: N/A | Run Off %: N/A | Run Off %: 0.00% |
| Avg 24hr Run-Off %: N/A | Avg 24hr Run-Off %: N/A | Avg 24hr Run-Off %: N/A | Avg 24hr Run-Off %: N/A | Avg 24hr Run-Off %: N/A | Avg 24hr Run-Off %: 45.65% |
| Run-Off 24hr: 25.00% | Run-Off 24hr: N/A | Run-Off 24hr: N/A | Run-Off 24hr: N/A | Run-Off 24hr: N/A | Run-Off 24hr: 0.00% |
| pH In: 5.60 | Run-Off 24hr: 50.00% | Run-Off 24hr: 45.00% | Run-Off 24hr: 26.00% | Run-Off 24hr: 25.00% | pH In: 6.54 |
| pH Out: 6.20 | pH In: 5.70 | pH In: 5.70 | pH In: 5.40 | pH In: 5.60 | pH Out: 6.78 |
| pH Bag: 6.60 | pH Out: 7.00 | pH Out: 7.00 | pH Out: 7.10 | pH Out: 6.70 | pH Bag: 6.70 |
| Ec In: 1.10 | pH Bag: 6.50 | pH Bag: 6.50 | pH Bag: 6.40 | pH Bag: 6.80 | Ec In: 0.5827 |
| Ec Out: 1.30 | Ec In: 1.00 | Ec In: 1.00 | Ec In: 0.90 | Ec In: 0.90 | Ec Out: 1.3447 |
| Ec Bag: 1.55 | Ec Out: 1.20 | Ec Out: 1.20 | Ec Out: 1.30 | Ec Out: 1.10 | Ec Bag: 1.90 |
| Ec Sum: 2.40 | Ec Bag: 1.46 | Ec Bag: 1.46 | Ec Bag: 1.42 | Ec Bag: 1.85 | Ec Sum: N/A |
| Ambient Temp: N/A | Ec Sum: 2.20 | Ec Sum: 2.20 | Ec Sum: 2.20 | Ec Sum: 2.00 | Ambient Temp: 15.27°C |
| Humidity: N/A | Ambient Temp: 15.04°C | Ambient Temp: 15.01°C | Ambient Temp: 15.14°C | Ambient Temp: 15.07°C | Humidity: 82% |
| VPD: N/A | Humidity: 81% | Humidity: 82% | Humidity: 82% | Humidity: 80% | VPD: 3.07 |
| Mildew Risk: N/A | VPD: 3.24 | VPD: 3.07 | VPD: 3.07 | VPD: 3.41 | Mildew Risk: 15 hours |
| | Mildew Risk: N/A | Mildew Risk: 17 hours | Mildew Risk: 12 hours | Mildew Risk: 15 hours | |


Agri-tech Client Dashboard and Charting Tools



Dashboard Menus

The Fields option 1 is the option to choose to get back to the dashboard list of all fields.

Hitting the Name of the block you are in at the top of the charts will bring up the "Switch to another field" box from where you can quickly choose the next field's charts without the need to return to the dashboard Field List



Menu:

- 1) Takes you back to the dashboard
- 2) Meeting reports where applicable
- 3) Switch charts on / off as appropriate
- 4) Click and drag charts to re-order you charts
- 5) Hide menu / reveal menu

NB The same menu layout will appear to the left of the field list on the main dashboard - features 3-6 will have the same functionality - hide or reveal field list and re-order the list

In chart view mode - choose your selected date range – default 10 days

Click on the timer icon to reveal timer and date range at the bottom of the screen highlighted




Agri-tech Client Dashboard and Charting Tools (substrate)

Substrate charts


- Rootzone moisture content chart indicating moisture parameters, squeeze test references, crop growth stages and any additional comments
- Run-off chart displaying individual irrigations applied, run-off from each event and percentage run-off from each event – now with the new 24 hr resolution option to display daily summaries of drip / drain volumes & % run-off
- Soil moisture content chart in bag / pot indicating uniformity
- New - Crop water usage chart indicating crop daily water use in mm – new icon circled in red indicating how to switch on 24hr resolution of water use

Zoom in / out / re-set & menu options



Substrate climate sensor charts

- Ambient temperature and humidity chart
- Vapour Pressure Deficit (VPD) chart
- Growing Degree Hour (GDH) chart
- Chill chart (not displayed)
- Optional - Strawberry Powdery Mildew prediction system




Farming Services & solutions to Agriculture & Horticulture


Substrate charts

Zoomed run-off chart clearly indicating when the drain occurred, with dashboard view of 24hr drain readings

| Name | Moisture | Water Usage | Conductivity | Soil Temp | Run Off % | Avg 24hr Run-Off % | Run-Off 24hr | pH In | pH Out | pH Bag | Ec In | Ec Out | Ec Bag | Ec Sum | Ambient Temp | Humidity | VPD | Mildew Risk |
|---------------------|----------|-------------|--------------|-----------|-----------|--------------------|--------------|-------|--------|--------|--------|--------|--------|--------|--------------|----------|------|-------------|
| BARN FIELD PRIZE 22 | 24.14 | -9.02 | 1.64 | 14.52 | 0.00% | 45.65% | 0.00% | 6.54 | 6.77 | 6.70 | 0.5843 | 1.3507 | 1.90 | N/A | 14.31°C | 84% | 2.56 | 15 hours |



Agri-tech Client Dashboard and Charting Tools



Adding data

By clicking on to the yellow pencil icon - see 1 above gives the option to add data



Choose either Fungicide spray activity / Record Agronomics / Record Observation



Provide the Observation details:

Times tamp
08/10/22 18:34

Type
Easy-Medium Squeeze

BACK SAVE

SAVE AND ADD ANOTHER



Provide the Agronomics data:

Times tamp
09/10/22 01:50

Run-Off 24hr
Run-Off 24hr

pH In

pH Out

pH Bag

Ec In

Ec Out

Ec Bag



Provide details of the spray activity:

Times tamp
08/10/22 18:35

Chemical
Chemical

Amount

Active Ingredient

BACK SAVE

BACK SAVE

SAVE AND ADD ANOTHER

Agri-tech Client Dashboard and Charting Tools (soil)

Farming Services & solutions to Agriculture & Horticulture

ATS Soil Dashboard

“Fuel gauge” indicating moisture status, SMD displayed in mm, and previous 24 hr water use in mm

Irrigation trigger and predicted irrigation date based on the previous 24hr water use

Additional sensor options such as a rain gauge, temperature and humidity sensor

| Name | Moisture | SMD | 24hr Water Usage | Irr. Trigger | Predicted Irrigation | Rainfall | Ambient Temp | Humidity |
|----------------------|----------|--------|------------------|--------------|----------------------|----------|--------------|----------|
| AGRI-TECH SOIL FIELD | | 221.52 | 8.18 | 0.10 | 200.00 | 03/03/23 | N/A | N/A |
| ATS CARROTS | | 77.06 | 28.94 | 5.41 | 61.00 | 30/07/22 | N/A | N/A |
| ATS POTATOES | | 77.09 | 23.91 | 3.23 | 66.00 | 31/07/22 | N/A | N/A |
| ATS ONIONS | | 98.32 | 8.68 | 4.68 | 82.00 | 31/07/22 | N/A | N/A |

Farming Services & solutions to Agriculture & Horticulture

Soil charts for data evaluation

Soil conductivity chart also available – indicative of nutrient status of each soil zone

Zoom in / out / re-set & menu options

ROOT-ZONE MOISTURE CONTENT

Summary of rootzone moisture (mm)
New red dot indicating comment –hover mouse over to view

SOIL MOISTURE CONTENT

Chart indicating where the roots are using water and what impact rain / irrigation is having on the soil profile

Switch sensors on / off to make viewing easy – click on the sensor name

CROP WATER USAGE & GAINS

Crop daily water use chart (mm)
Red circle highlighting new icon for switching on 24 hr crop use bar chart

SOIL TEMPERATURE

Soil temperature at each depth (Celsius)


Agri-tech Client Dashboard and Charting Tools (soil)

Using rootzone water content chart and crop water use to determine irrigation trigger – drilled onions

Optimum crop water use declines at differing stages through the growing season as the rootzone develops (highlighted red circles)

The irrigation trigger will alter accordingly, therefore ensuring optimum moisture is provided for the plant to utilise at any given point in time

The new crop daily water use chart providing key data for precision irrigation scheduling



SMART sensor data – updating every ¼ hr via the cloud directly into the client dashboard

Up to date data at your fingertips to enable decisions and precise scheduling to take place



Soil charts for data evaluation

Soil conductivity chart also available – indicative of nutrient status of each soil zone

Zoom in / out / re-set & menu options

